



**NOTES:**

1. This standard provides recommended barrier protection for pad mounted equipment subject to vehicular traffic.
2. Posts may be omitted on side (s) not subject to vehicular traffic.
3. Barriers must not interfere with the operation of pad mount equipment by CEL&P personnel.
4. A 3-1/2" heavy wall steel, concrete filled lally column purchased from local lumber yard is acceptable. Bearing plates must be removed. Set posts in concrete (see Detail A)
5. Install additional posts on sides or back as required to maintain maximum 48" spacing.



PROTECTION FOR EQUIPMENT SUBJECT TO  
VEHICULAR TRAFFIC