



NOTES:

1. ENTIRE STRUCTURE TO BE CONSTRUCTED AND INSTALLED BY THE CONTRACTOR.
2. THE USE OF THIS STRUCTURE IS NOT PERMITTED IF SERVICE WIRES PASS OVER PUBLIC STREETS, ALLEYS, ROADS, AND DRIVEWAYS.
3. TEMPORARY SERVICE POLE MUST BE A MINIMUM OF 10 FT. FROM CEL&P POLE AND MUST BE POSITIONED TO ALLOW THE SERVICE DROP TO CLEAR THE IBT AND CATV CABLES BY AT LEAST 40 INCHES.
4. ALL SERVICES SHALL BE GROUNDED BY 0" X 8' OR 0" X 10' GROUND ROD.



**TEMPORARY OVERHEAD SERVICE
60 TO 100 AMP 240 VOLT
SINGLE PHASE, 3 WIRE**