



NOTE:
 CONTRACTOR TO FURNISH AND INSTALL A MINIMUM
 SIZE 3/8" GALVANIZED LAG SCREW EYE OR EYE
 BOLT OR HOUSE KNOB FOR ATTACHMENT OF SERVICE DROP.



**TRIPLEX SERVICE
 CONNECTION BELOW ROOF
 MAXIMUM 200 A**